

PO Box 1553 6 Du Plooy str
Potchefstroom Potchefstroom
2521 2531

Tel: 0182944283 envirocare@safricom.co.za
Cel: 0847906971



Final Test Report

Client Name:	Company:	Contact Number:	Email:	Address:
Stenly Makuwa	JB Marks	076 187 0786	stenlym@jbmarks.gov.za	Luiting straat, Potchefstroom

Result Information:

Reference:	Order Placed:	Analysis started:	Submission date:
JB Marks_211210	10.12.2021	12.10.2021	14.12.2021
Samples received Date:	Sampler:	Sample Site:	Final completion:
10.12.2021	Client	N/A	14.12.2021

Results: Water

Sample ID	Total plate count TEC-08 Cfu/1ml	Total coliforms TEC-27 Cfu/100ml	Faecal coliforms TEC-10 Cfu/100ml	E.coli TEC-27 Cfu/100ml
R1	17	2	<1	<1
R2	7	3	<1	<1

Abbreviations and remarks:

Cfu: colony forming units

<1: None detected

- Envirocare endeavours to perform correct analyses.
- Results relate only to the sample as received by the laboratory. When samples are supplied by the customer, the customer is responsible for correct sampling techniques and sample identification.
- Results identified with a "*" in this report are not included in the SANAS schedule of accreditation for this Laboratory. Results identified with a "#" in this report are sub-contracted for the required analysis.
- The Laboratory does not give any opinions and interpretations as that falls outside the scope of accreditation.

Technical signatory

****End of Report****